



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

Date of Assessment February 2020

Risk Assessment Produced by the Committee

A review of the Fire Risk Assessment should be carried out annually and whenever a material change to the building or its usage takes place.

### FIRE HAZARDS AND THEIR ELIMINATION OR CONTROL

#### 1. ELECTRICAL SOURCE OF IGNITION

NO:	GENERAL	YES / NO	RESULT
1.1	Reasonable measures taken to prevent fires of an electrical origin	Yes	Yes
1.2	Fixed installation inspected and tested	Yes	annually
1.3	Portable Appliance Testing	Yes	Bi-annually



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

1.4	<p><b>Policy on use of personal electrical appliances</b></p> <p><b><u>ELECTRICAL APPLIANCE SAFETY:</u></b>            The HIRER shall ensure that any electrical appliance brought in by them to the premises and used there shall be safe, in good working order, and used in a safe manner in accordance with the <b>ELECTRICITY AT WORK REGULATION 1989</b>. Any damage caused to the Village Hall as the result of electrical appliances brought into the Village Hall shall be the responsibility of the Hirer.</p>	Yes – By Hirer	OVH Standard Conditions of Hire
-----	---	----------------	---------------------------------

### 2. SMOKING

NO:	GENERAL	YES / NO	RESULT
2.1	<p>Reasonable measures taken to prevent fires as a result of Smoking.            The HIRER shall ensure that <b>NO SMOKING</b> or vaping (E-cigarettes) allowed anywhere inside the Village Hall or the Hall Porch area.</p>	Yes – By Hirer	OVH Standard Conditions of Hire
2.2	Smoking, vaping and smoking of e-cig banned in the building	Yes	No smoking & Vaping signs in place
2.3	Approved signage displayed	Yes	Yes
2.4	<p>Arrangements for those who smoke:            A cigarette stub box is provided on the wall outside the Village Hall</p>	Yes	Yes



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

### 3. PORTABLE HEATERS

NO:	GENERAL	YES / NO	RESULT
3.1	<p>No portable heaters to be used, main heating is provided by oil fired radiators. Hot water is provided by electric heater.</p> <p><b><u>NO PORTABLE LIQUID PROPANE OR LPG HEATING APPLIANCES SHALL BE USED.</u></b></p>	Yes – By Hirer	OVH Standard Conditions of Hire

### 4. COOKING

NO:	GENERAL	YES / NO	RESULT
4.1	Suitable extinguishing appliances available	Yes	Yes. Checked by Keith Preston and annually Ball Fire Protection
4.2	Hazards observed	Yes – By Hirer and Committee	Yes

### 5. OTHER SIGNIFICANT IGNITION SOURCES – Portable Equipment (PAT Test)

NO:	GENERAL	YES / NO	RESULT



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

5.1	Vacuum Cleaners	Yes	Yes
5.2	Kettles	Yes	Yes
5.3	Urn	Yes	Yes
5.4	Microwave	Yes	Yes

### 6. ARSON

NO:	GENERAL	YES / NO	RESULT
6.1	Is there an absence of fire load material in close proximity to building or available for ignition by outsiders	Yes	Monthly check. Users aware of suitable place to store rubbish etc.
6.2	Wheelie bin placed near building – rubbish and recycling	Yes	Rubbish & recycling bin is sited next to the oil tank on private land.



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

### FIRE PROTECTION MEASURES

#### 7. MEANS OF ESCAPE

NO:	GENERAL	YES / NO	RESULT
7.1	Premises provided with reasonable means of escape	Yes	Yes
7.2	Adequate provision of escape routes	Yes	Yes
7.3	Reasonable means of escape for disabled people	Yes	On ground floor only
7.4	Are escape routes clear and unobstructed	Yes – By Hirer Yes – By Committee	OVH Standard Conditions of Hire
7.5	Hazards Noted	Yes	Reviewed during monthly fire checks
7.6	Do all emergency fastening devices to fire exits work correctly	Yes	Yes
7.7	Do all opening doors work correctly	Yes	Yes



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

### 8. ESCAPE AND EMERGENCY LIGHTING

NO:	GENERAL	YES / NO	RESULT
8.1	Escape lighting complies with regulations	Yes	Yes
8.2	Are all luminaries and illuminated signs adequate and in good working order?	Yes	Yes
8.3	Does the emergency lighting system seem to be working	Yes	Yes
8.4	Is the system energised at least once a month	Yes	Yes - By nominated person

### 9. FIRE SAFETY SIGNS AND NOTICES

NO:	GENERAL	YES / NO	RESULT
9.1	Are there sufficient notices that display the action to be taken in case of a fire	Yes	Yes
9.2	Are there notices that display the location of the assembly point?	Yes	Yes
9.3	All extinguishers and notices have photo-luminescent signage	Yes	Yes



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

### 10. FIRE ALARM SYSTEMS

NO:	GENERAL	YES / NO	RESULT
10.1	Type of fire alarm system installed	Yes	Firetrax Professional
10.2	Is the alarm tested at least once a week for function?	Yes	By nominated person
10.3	Does a competent person test the fire alarm quarterly or annually?	Yes	6 monthly – January and July By: CJG Fire Protection
10.4	Are there sufficient call points	Yes	Yes
10.5	Name of Fire Alarm contractor	Yes	CJG Fire Protection
10.6	Where is the main control panel situated	Yes	Inside the front door on the left
10.7	Are the results of the fire alarm tests recorded in a log book	Yes	By Nominated Person
10.8	Is a plan showing fire alarm zones sited next to the alarm panel	Yes	Yes on notice board in entrance corridor

### 11. MANUAL FIRE EXTINGUISHING APPLIANCES

NO:	GENERAL	YES / NO	RESULT
11.1	Reasonable provision of portable extinguishers	Yes	Yes
11.2	Have all extinguishers photo-luminescent signage	Yes	Yes
11.3	Is a fire blanket available in the kitchen	Yes	Yes



## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

11.4	Does a competent person check the firefighting equipment at least once a year?	Yes	Ball Fire Protection

### MANAGEMENT OF FIRESAFETY

#### 12. PROCEDURES AND ARRANGEMENTS

NO:	GENERAL	YES / NO	RESULT
12.1	Persons responsible for fire safety	Yes	Keith Preston and Pete Cashin
12.2	Appropriate fire procedure in place	Yes	OVH Standard Conditions of Hire

#### 13. TESTING AND MAINTENANCE

NO:	GENERAL	YES / NO	RESULT
13.1	Annual servicing of fire extinguisher equipment	Yes	May each year by Ball Fire Protection
13.2	Regular testing routines in place for emergency lighting system	Yes	By Nominated Person





## Otterhampton Village Hall Fire Risk Assessment

1<sup>st</sup> February 2020

13.3	Routine checks on final exit doors	Yes	By Nominated Person
13.4	Regular inspections of premises	Yes	By Nominated Person

### 14. OTHER FIRE RISKS

NO:	GENERAL	YES / NO	RESULT
14.1	Are flammable liquids used or stored on the premises, if yes what materials are stored?	Yes	Oil tank outside
14.2	Is the use of extension leads and multi-point adaptors kept to a minimum?	Yes	Yes
14.3	Are there any other matters that give cause for concern?	No	No